VALVE BOX ASSEMBLY - Type I, Type II

FOR USE IN CONCRETE SURFACED AREAS (Low speed vehicular traffic only)

OTYPE II TYPE I Valve box shall be 3.RT Series as Valve box shall be 4.TT Series with manufactured by Brooks Products Inc., 2"riser ring as manufactured by C.I. traffic cover shall be marked "WATER". Brooks Products Inc., C.I. traffic cover shall be marked "WATER". Finish surface 8"PVC PIPE, diameter (outside) = 9.05"max. Center line of B" PVC pipe and operating nut. Watermain

NOTE: For typical installation with one pressure zone in vicinity, use Type II valve box assembly. When separate pressure zones are located in the same vicinity, valves on the mainline of the zone with the higher static pressure shall have Type I valve box assembly installed.

Valve

Drawn by: JSWilliams Date: January 28, 1985
Revised by: JSWilliams Date: March 16, 2004

Effective Date: April 13, 2004



City of Glendora Public Works Department STANDARD DESIGNS & SPECIFICATIONS

Adopted for use on Public and Private Improvements

S.D.& S. NO.

2.16

Page 1 of 1